IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Creek Co RWD # 2 Did Not Meet Monitoring Requirements

Our water system violated drinking water requirements pertaining to the contaminant(s) of concern listed below. Although none of these violations are considered emergencies, as our customers, you have a right to know what happened and what we are doing, or have done, to correct these violations. Customers are not at risk and there is no reason to suspect any potential adverse health effects. Alternative water supplies are not needed.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During the following monitoring periods, we did not monitor or test for the following contaminants, and therefore cannot be sure of the quality of your drinking water during that time:

Type of Sample(s)	Monitoring Period(s)
CHLORINE	5/15/2024 to 5/31/2024
TOTAL COLIFORM	5/15/2024 to 5/31/2024

What should 1 do? No action is required

What happened? What is being done? <u>During the month of May 2024 our district was required to collect 15 total Coliform and Chlorine residual samples.</u> Our district failed to meet the required deadline for the second half of May leaving our district short 10 samples for that month. However, our district promptly gathered those 10 samples from the pre-determined sites along with the first half of June's 10 required sample sites and all 20 passed.

We anticipate resolving the problem by this date: The problem has been resolved.

For more information, please contact: Matt Foreman at (918) 299-4448 or Juan Loera at (918)830-1529

2425 W 121st S. Jenks, Ok. 74037

Please share this information with all other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWSID No. OK3001902 County: Creek Date PN Distributed: 8/20/2024